

## APPENDIX N

# INSPECTION, TESTING AND MAINTENANCE OF NON-WATER BASED KITCHEN FIRE SUPPRESSION SYSTEMS

*The provisions and form(s) contained in this appendix are mandatory.*

## SECTION N101 GENERAL

**N101.1 Scope.** Every permitted and certified contractor in the non-water based kitchen fire suppression system industry shall utilize one standardized form, set forth at Section N101.2, for documenting the required inspections, testing and maintenance of non-water based NFPA 17 and NFPA 17A kitchen fire suppression systems. Every permitted and certified contractor in the non-water based kitchen fire suppression system industry shall provide a copy of the completed standardized form to both the owner or occupant and the local fire code enforcement official within five business days of inspection, testing and maintenance.

**N101.2 Annual Inspection of Non-Water Based Kitchen Fire Suppression System Form:**